



Jim Doyle, Governor
Jack L. Fischer, A.I.A., Secretary

April 15, 2008

SFA SANIFLO
ROBERT LECHNER
105 NEWFIELD AVE STE A
EDISON NJ 08837

SFA SANIFLO INC.
JOHAN BOUWER
105 NEWFIELD AVE SUITE A
EDISON NJ 08837

Re: Description: MACERATING PUMP SYSTEM
Manufacturer: SFA SANIFLO INC.
Product Name: SANIGRIND AND SANIPACK
Model Number(s): SANIGRIND MACERATING PUMP
Product File No: 20070545

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2013.

This approval is contingent upon compliance with the following stipulation(s):

- The water closet that discharges to the SANIFLO macerating Sanigrind and Sanipack sewage pump must not discharge more than 1.6 gallons per flush.
- The discharge pipe must connect to a sanitary drain system in accordance with Comm 82.30 (10) of the Wisconsin Administrative code.
- This product MAY NOT serve a shower unit.
- This product may only serve a toilet, lavatory, and/or a bathtub, with or without shower.
- The venting system serving the macerating unit must conform to requirements of Comm 82.31 of the Wisconsin Administrative code, "vents for sumps".

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: Jerry.Thompson@wi.gov